

Main Office Oslo:
Forskningsveien 3b
Mail address:
P.O Box 123 Blindern
N-0314 OSLO
Telephone: +47 22 96 55 00
Telefax: +47 22 69 94 38
Postal giro: 0806 4 160 495
Bank giro: 5084.05.10058
Enterpr.No: NO 943 813 361

* Trondheim division:
Høgskoleringen 7
Mail address:
Høgskoleringen 7
N-7034 TRONDHEIM
Telephone: +47 73 59 33 90
Telefax: +47 73 59 33 80

Project No.: O8030B	Place / Date: Oslo 18.05.95
Head of project / author: Tore Kvande	
Client's name: BS Norge	
Client's address: Postbox 30, 5031 LAKSEVÅG	
Client's reference: Roy Eide	

REPORT

MEASURING OF THE PENETRATION DEPTH IN CONCRETE OF THE IMPREGNATION AGENT "CONTROL"

Brief summary:

The Norwegian Building Research Institute has determined the penetration depth in concrete of the impregnating agent "Control".

The method

The test was carried out according to a test method described by the client. Pools on top of the specimens of concrete with compressive strength 25 N/mm², were filled up with either "Control" added pigment or pigmented water. The pigment made it possible to define the depth of the penetration after splitting the specimens.

Results

Measured depth of penetration: Control 195 mm
Water 45 mm

Permanent subject words: Field examination Lab.examination Investigation Calculation Damage

Other approved subject words: BETONG PÅSTRYKNINGS- MIDDEL	Address of the building :	Our ref.: TOK/GD <i>Tok</i>
	When built (year):	Quality assurance: AMW <i>AMW</i> Responsible signature: TJA <i>TJA</i>